Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 02/26. Dated: 12/11/2026.

It is certified that an inspection team headed by ....Dr. Vibha.V.....

(Name of Officers with designation) from ....Superintendent of TH Perambra (ic) PHED

inspected the ....St. Meera's Public School Perambra Kallode....

(Name & Address of the school) on 06/11/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. KWA/KKD/PMY/0704/26 dated 07/11/26

of .....KWA..... (PHED Lab) certified that the ....St. Meera's Public School/.....(Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till ....05-11-2027....

TALUK HOSPITAL ★ PERAMBRA P.O. KOZHIKODE- 673 525 Date: 12/11/26

Signature with Seal: .....

Name : ...Dr. Vibha. V.....

Designation : ....Assistant Surgeon.....

Name & Address of the Office / Department : .....

Dr. Vibha V. MBBS
Assistant Surgeon
Reg. No: 28213

....the Headmistress.....

....St. Meera's Public School Perambra

(Name & Address of the Institution)

സുപ്രണ്ട്
താലൂക്ക് ആശുപത്രി
പേരാമ്പ്ര-673525

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Scanned with OKEN Scanner

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB
KUTTIADY
KOZHIKODE
NABL RECOGNISED DRINKING WATER TESTING LABORATORY
E-mail: waterqualityktdy@gmail.com

TEST REPORT

Report No - KWA/KKD/KTDY/3913/2026 *Date of Report: 03/11/2026*

Customer Name & Address		
MOLYKKUTTY ABRAHAM *9048239757*	*1.Sample received on*	*: 31/10/2026*
	2.Sample Condition	*: FIT FOR ANALYSIS*
	3.Sampling done by	*: PARTY*
	4.Sample Ref. No:	*: NIL*
	5.Sample code	*: 3913/2026*
	6.Source of sample	*: BORE WELL WATER*
	7.Sample quantity	*: 1LTR*
	8.Test performing dates	From : 31/10/2026 To: 03/11/2026

Sl. No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	*Result*
1	Colour	HU	IS 3025 (part 4)-2021 (PLATINUM COBALT VISUAL COMPARISON METHOD)	< 5.0	ND
2	Odour		IS 3025 (part 5)-2018	Agreeable	ND
3	Turbidity	(NTU)	IS 3025 (part 10)-1984 (NEPHLOMETRIC METHOD)	1	3.62
4	pH at 25 °C		IS 3025 (PART 11)-2022	6.5 to 8.5	6.61
5	Alkalinity (as $CaCo_3$)	(mg/litre)	IS 3025 (PART 23)-1986 (INDICATOR METHOD)	200	<5.0
6	Total Dissolved Solids at 180°C (TDS)	(mg/litre)	IS 3025 (part 16)-2023 (GRAVIMETRIC METHOD)	500	49.0
7	Total Hardness (as $CaCo_3$)	(mg/litre)	IS 3025 (part 21)-2009 (EDTA METHOD)	200	30.0
8	Calcium (as Ca)	(mg/litre)	IS 3025 (part 40)-1991 (EDTA METHOD)	75	5.61
9	Magnesium (as Mg)	(mg/litre)	IS 3025 (part 46)-1994 (TITRATION METHOD)	30	<5.0
10.	Chloride (as Cl)	(mg/litre)	IS 3025 (part 32)-1988 (ARGENTOMETRIC METHOD)	250	<5.0

Remarks:- *The results reported relate only to the sample received and tested. This test Report shall not be reproduced except in full without the written approval of the Laboratory.*

Reviewed By: Chemist

Authorized By : Ershad O.C

End of Report

SUB DISTRICT LABORATORY
KUTTIADY, KOZHIKODE

Scanned with OKEN Scanner

KERALA WATER AUTHORITY

QUALITY CONTROL SUB DISTRICT LAB
KUTTIADY, KOZHIKODE

E-mail: waterqualityktdy@gmail.com

TEST REPORT

Report No - KWA/KKD/KTDY/3913/2026 Date of Report: 03/11/2026

Customer Name & Address		
MOLYKKUTTY ABRAHAM 9048239757	1.Sample received on	: 31/10/2026
	2.Sample Condition	: FIT FOR ANALYSIS
	3.Sampling done by	: PARTY
	4.Sample Ref. No:	: NIL
	5.Sample code	: 3913/2026
	6.Source of sample	: BORE WELL WATER
	7.Sample quantity	: 1LTR
	8.Test performing dates	From : 31/10/2026 To: 03/11/2026

Sl. No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Electrical conductivity at 25°C	(micro mhos/cm)	IS 3025 (part 14)-2013 (Reaffirmed 2019)		75.98
2	Acidity	(mg/litre)	IS 3025 (part 22)-1986 (Reaffirmed 2019)	3	-
3	Sulphate (as SO_4)	(mg/litre)	IS 3025 (PART 24)-1986 (Reaffirmed 2019)	200	0.1
4	Phosphate [as PO4]	(mg/litre)	IS 3025 (PART 31)-2008 (Reaffirmed 2019)		ABSENT
5	Fluoride (as F)	(mg/litre)	APHA 4500F-D 23rd Edition	1.0	BDL
6	Iron (as Fe)	(mg/litre)	IS 3025 (part 53)-2003 (Reaffirmed 2014)	1.0	0.8
7	Nitrate (as NO_3)	(mg/litre)	APHA4500NO3-B 23rd Edition	45	5.0
8	Ammonia	(mg/litre)	IS 3025 (part 34)-2008 (Reaffirmed 2019)	0.5	0.1
9	Residual Chlorine	(mg/litre)	IS 3025 (part 26)-1986 (Reaffirmed 2019)	0.2	ND

*ND→Not Detected *BDL→Below Detectable Limit

Remarks:- *The results reported relate only to the sample received and tested. This test Report shall not be reproduced except in full without the written approval of the Laboratory.*

Reviewed By: Chemist

KUTTIADY 673508

Authorized By :

DEPUTY QUALITY CONTROL MANAGER
KERALA WATER AUTHORITY
SUB DISTRICT LAB (QC)
KUTTIADY, KOZHIKODE

End of Report

Scanned with OKEN Scanner

KERALA WATER AUTHORITY

QUALITY CONTROL SUB DISTRICT LAB
KUTTIADY, KOZHIKODE

E-mail: waterqualityktdy@gmail.com

Report No - KWA/KKD/KTDY/3913/2026 Date of Report: 03/11/2026

Customer Name & Address		
MOLYKKUTTY ABRAHAM 9048239757	1.Sample received on	: 31/10/2026
	2.Sample Condition	: FIT FOR ANALYSIS
	3.Sampling done by	: PARTY
	4.Sample Ref. No:	: NIL
	5.Sample code	: 3913/2026
	6.Source of sample	: BORE WELL WATER
	7.Sample quantity	: 100 ML
	8.Test performing dates	From : 31/10/2026 To: 03/11/2026

Sl. No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Coliforms	CFU/100ml	IS 15185(part1) 2002 reaffirmed2016	Shall not be detectable in any 100ml sample	NIL
2	E coli	CFU/100ml	IS 15185(part1) 2002 reaffirmed2016	Shall not be detectable in any 100ml sample	NIL

*TNTC → Too Numerous To Count (COLIFORM COUNT ABOVE 300CFU/100 ml)

Remarks:- *The results reported relate only to the sample received and tested. This test Report shall not be reproduced except in full without the written approval of the Laboratory.*

Authorized By :

DEPUTY QUALITY CONTROL OFFICER
KERALA WATER AUTHORITY
SUB DISTRICT LAB
KUTTIADY, KOZHIKODE

Scanned with OKEN Scanner